

**Bear Valley Electric Service, Inc. (BVES)
Planned Outage Supplement to the 2022 Annual Electric Reliability
Report**

(D.16-01-008, Updating the Annual Electric Reliability Reporting Requirements for California
Electric Utilities)

July 17, 2023

**Planned Outage Report
(2022)**

The table below provides the list of planned outages in the BVES Service Area for 2022.

Outage Date	Circuit	Number of Customers Out	Outage Duration	Customer Minutes Out	Event SAIDI	Description of Cause
1/6/22	North Shore	20	76	1520	0.062	Installed junction bars and cable in Vault 022 (new construction)
1/27/22	Erwin Lake	60	24	1440	0.058	Pole replacement and wire transfer
1/27/22	Erwin Lake	30	376	11280	0.457	Pole replacement and wire transfer
1/27/22	Erwin Lake	60	12	720	0.029	Pole replacement and wire transfer
3/18/22	Lagonita	1	240	240	0.010	3 single phase 75kVA Padmount transformer replaced
7/13/22	Holdcomb	9	90	810	0.033	Pole replacement and wire transfer
10/6/22	Clubview	44	540	23760	0.962	Re-conductor and replace poles
10/6/22	Clubview	6	1500	9000	0.364	Re-conductor and replace poles
12/16/22	Shay	7108	3	21324	0.863	SCADA Testing at Moonridge Substation, 4kV VFI-2 Way 3 cross phased at this location. Substations off include: Maple, Bear Mountain, Moonridge and Summit