

Bear Valley Electric Service

P.O. BOX 1547 42020 GARSTIN DR BIG BEAR LAKE, CA. 92315

A Division of Golden State Water Company

Telephone (909) 866-4678

Engineering: Ext. #142

Service Connection & Scheduling: Ext. #161

Recommended Installation - Temporary Underground Service

- A.) All temporary poles are to be installed by the customer or their contractor. **NOTE: A Preliminary Service Request is required on all new service connections.**
- B.) BVES will charge a \$75.00 fee for a temporary hook-up. BVES will furnish and install the meter, conductor, and connectors.
- C.) Permits and inspections must be obtained from the following agencies, depending on service location :
- City of Big Bear Lake
39707 Big Bear Blvd
(909) 866-5831
Big Bear Lake, CA 92315

or: County of San Bernardino
477 Summit Blvd
Big Bear Lake, CA 92315
(909) 866-0170

It is the customer's responsibility to notify or supply BVES with a "Green-Tag" or "Inspection Notification" before service can be connected. Time frames for all new connections are contingent upon current work loads.

- D.) Minimum Trenching Requirements:
- A.) Minimum depth of no less than 18", to be provided by customer.
- B.) Backfill not to contain any rocks more than 1/2" in diameter.
- E.) The recommended installation exceeds the minimum NEC requirements. NEC minimums are also acceptable.
- F.) For any service larger than 100 amps, consult Engineering Department Representative.
- G.) Poles will be installed 5' to 10' from existing BVES facilities.
- H.) Floodlights, signs, ropes, and other similar equipment, shall not be attached to service or the temporary pole.

