



NOTES:

1. SIZE AND DIMENSIONS OF PANELS WILL VARY. DRAWINGS ARE NOT TO SCALE.
2. THIS DRAWING PERTAINS TO BOTH OVERHEAD AND UNDERGROUND ELECTRIC SERVICE APPLICATIONS.
3. MAINTAIN A THREE-FOOT CLEAR LEVEL, AND UNOBSTRUCTED WORK SPACE IN FRONT OF ELECTRIC SERVICE EQUIPMENT.
4. PLUMBING FIXTURES THAT EXTEND MORE THAN SIX (6) INCHES OUT FROM WALL SURFACE MUST BE LOCATED 18-INCHES MINIMUM FROM THE OUTSIDE EDGE OF THE METER PANEL.

APPROVED BY:

MA

SEPARATION OF METER ASSEMBLIES FOR ELECTRIC AND GAS SERVICES

OTHER NOTES _____