



NOTES:

1. \* Check the Acceptability Tables for utility requirements.
2. All AC disconnect switches shall be load break rated.
3. A safety socket may be required. Consult your local utility.
4. A minimum 10" clearance is required from the edge of any enclosure.
5. Drawing 300, subsection III.I shall apply up to and including the Net/Performance meter.

ALL DIMENSIONS SHOWN ARE IN INCHES

REV.	DATE	DESCRIPTION
	11/12	NEW DRAWING - PROJECT #12-02-01
SCALE	N.T.S.	TYPICAL SERVICE WITH LOAD SIDE INTERCONNECTION
DATE	11/12	ELECTRIC UTILITY SERVICE EQUIPMENT REQUIREMENTS COMMITTEE
		SHT 1 OF 1
		DWG NO. 502      REV.